

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. NO/THO/AKL/260/2026-27

Dated: 29-09-2026

It is certified that an inspection team headed by **Dr. Ravi C R, Medical Officer, Anekal Tq** . (Name of Officers with designation) from **Anekal Tq** inspected **St Josephs school, Jnana Jyothi, Attibele Road, Anekal Taluk, Bangalore Urban Dist – 562106**. (Name & Address of the school) on 29/09/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing No: IATL026/09/SCW/027 dated 28-09-2026 of **District Water Quality Testing Lab, RDW & SD Anekal** certified that the **ST JOSEPHS SCHOOL** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/U.T. Govt.

This certificate is valid till 28-09-2027

Signature with Seal:


Signature with Seal:

Name: **Dr. RAVI C.R**

Designation: **Taluk Health Officer**

TALUK HEALTH OFFICER

ANEKAL TALUK

BANGALORE URBAN DISTRICT

To

ST JOSEPHS SCHOOL,

Jnana Jyothi, Attibele Road,

Anekal Tq – 562106.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab / local bodies



INDIAN ANALYTICAL TESTING LABORATORY



An ISO 9001:2015 Certified Laboratory

No.3, 3rd Floor, A Main Road, North Layout, Nayandanahalli, Near Indian Oil Petrol Bunk, Bangalore: 560039, Karnataka.

Mob No: 7899440170/8553345681 E-Mail: iatlabservice@gmail.com Web site: iatlabs.com

TEST CERTIFICATE

Certificate No.: IATL026/09/SCW/027	Certificate Date: 28/09/2026
Issued To: ST. JOSEPH'S SCHOOL JNANA JYOTHI, OPPOSITE TO CIVIL COURT, ATTIBELE MAIN ROAD, ANEKAL-562106	Date of Receipt: 22/09/2026
	Sample Code.: IATL026/07/SCW/027
	Sample Collected By: Iatlab
Sample Description: Colorless, Transparent liquid	Description of Sample : RO-Drinking Water

Sl. No.	Parameters	Test Method (Reference)	Limits AS per 10500:2012	Results
01	Color, Hazen Units	IS 3025 (Part 4)	2 Unit	<1.0
02	Odor	IS 3025 (Part 5)	Agreeable	Agreeable
03	Taste	IS 3025 (Part 8)	Agreeable	Agreeable
04	Turbidity, NTU	IS 3025 (Part 10)	1.0 NTU	0.00
05	pH @ 25° C	IS 3025 (Part 11)	6.5 to 8.5	6.58
06	Chloride as Cl, mg/L	IS 3025 (Part 32)	250.0	8.00
07	Sulphate as SO ₄ , mg/L	IS 3025 (Part 24)	200.0	<1.00
08	Alkalinity as CaCO ₃ , mg/L	IS 3025 (Part 23)	200.0	12.00
09	Total Dissolved Solids, mg/L	IS 3025 (Part 16)	500.0	52.60
10	Residual Free Chlorine, mg/L	IS 3025 (Part 26)	0.2	BDL
11	Total Hardness as CaCO ₃ , mg/L	IS 3025 (Part 21)	200.0	20.00
12	Copper as Cu, mg/L	IS 3025 (Part 42)	0.05	0.001
13	Iron as Fe, mg/L	IS 3025 (Part 53)	0.10	0.002
14	Calcium as Ca, mg/L	IS 3025 (Part 40)	75.0	6.40
15	Magnesium as Mg, mg/L	IS 3025 (Part 46)	30.0	3.25
16	Nitrate as NO ₃ , mg/L	IS 3025 (Part 34)	45.0	<1.00
17	Aluminum as Al, mg/L	IS 3025 (Part 55)	0.03	<0.001
18	Nitrite as NO ₂ , mg/L	IS 3025 (Part 34)	0.02	<0.01
19	Fluoride as F, mg/L	IS 3025 /Part 60	1.0	0.01
20	Total Coliform, MPN/100 ml	IS:1622-1981	Not Detectable	Not Detected
21	E. coli, MPN/100 ml	IS: 1622-1981	Not Detectable	Not Detected

BDL-Below Detection Limit

Report Status: The tested water sample meets to acceptable limit as per IS 10500: 2012 for above Physical, Chemical and Microbiological Testing.

*****End of the Report*****

Analysed by: 



- Note: 1. The results listed pertain only to the tested samples and applicable parameters.
2. Sample will be destroyed after 15 days from the date of issue of test certificate unless & otherwise specified.
3. This report is not be reproduced either wholly or in part cannot be used an evidence in the court of law and should not be used In any advertising media without prior written permission.
4. Sampling not done by us, unless specified.